

EK 3-6-9


Boiler system for space heating

Model	EK 3 kW
Condensing boiler	No
Low-temperature boiler	No
B11 boiler	No
Cogeneration space heater	No
Combination heater	No


Item	Symbol	Value	Unit
Rated heat output	P_{rated}	2,914	kW
At rated heat output and high-temperature regime	P_d	2,914	kW

Model	EK 6 kW
Condensing boiler	No
Low-temperature boiler	No
B11 boiler	No
Cogeneration space heater	No
Combination heater	No

Item	Symbol	Value	Unit
Rated heat output	P_{rated}	5,914	kW
At rated heat output and high-temperature regime	P_d	5,914	kW




Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	η_s	39	%
At rated heat output and high-temperature regime	η_d	39	%
Other items			
Standby heat loss	P_{stby}	0,0864	kW



Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	η_s	39	%
At rated heat output and high-temperature regime	η_d	39	%
Other items			
Standby heat loss	P_{stby}	0,0864	kW

Model	EK 9 kW
Condensing boiler	No
Low-temperature boiler	No
B11 boiler	No
Cogeneration space heater	No
Combination heater	No



Item	Symbol	Value	Unit
Rated heat output	P_{rated}	8,914	kW
At rated heat output and high-temperature regime	P_d	8,914	kW

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	η_s	40	%
At rated heat output and high-temperature regime	η_d	40	%
Other items			
Standby heat loss	$P_{standby}$	0,0864	kW